

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470021	SCHOOL HILL ASSOCIATION, INC.			C	77	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Ethylene Dibromide (EDB) (2946)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470021	SCHOOL HILL ASSOCIATION, INC.			C	77	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION EXEMPTION	3/1/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	BETWEEN GAC FILTERS	5		A				
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GWS002	5 ELAINE DRIVE-KITCH	A	Y	3	Y	
		GWS003	9 ELAINE DRIVE-KITCH	A	Y	3		
		GWS004	20 ELAINE DRIVE-BATH	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470021	SCHOOL HILL ASSOCIATION, INC.			C	77	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served:

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		GWS005	6 HELENA DRIVE-KITCH	A	Y	3		
		GWS006	34 WINDSORVILLE RD	A	Y	3		
		GWS007	11 ELAINE DR	A	Y	3		
		GWS008	24 ELAINE DR	A	Y	3		
		GWS009	8 ELAINE DR	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
359	SCHOOL HILL PUMP HOUSE							
52	WELL 1	2	WELL 1	A				
53007	PRESSURE STORAGE							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2021
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021

Water System Facility: **SCHOOL HILL PUMP HOUSE (WSF ID: 359)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2021
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021

Contact Information

Name				Organization			Job Title		
School Hill Association, Inc.									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
C/O Treasurer			11 Elaine Drive			Broad Brook		CT	06016
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
				860-623-3089					
Contact Role(s):		Legal Contact							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0470021	SCHOOL HILL ASSOCIATION, INC.	C	77	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
		31			
Towns Served:					
Name		Organization		Job Title	
Ms. Karen Hanrahan		School Hill Association, Inc.		Secretary/Treasurer	
Mailing Address Line One		Mailing Address Line Two		City	State
11 Elaine Drive				Broad Brook	CT
Zip Code					
06016					
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-623-3089				860-623-5392	mgrouten@cox.net
Contact Role(s): Administrative Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470071	EAST WINDSOR HOUSING AUTHORITY			C	94	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1A PARK HILL			84				

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Nitrate (1040)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470071	EAST WINDSOR HOUSING AUTHORITY			C	94	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1A PARK HILL			84				

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate (1040)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Nitrite (1041)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Tritium (4102)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Strontium-90 (4174)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470071	EAST WINDSOR HOUSING AUTHORITY			C	94	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1A PARK HILL			84				

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2014	
CROSS CONNECTION EXEMPTION	3/1/2015	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2015	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-001	COMMUNITY HALL KITC	A	Y	1		
		4-002	1ST LEVEL LAUNDRY	A	Y	1		
		4-003	DISTRIBUTION ROOM	A	Y		Y	
		4-004	MAINTENANCE GARAGE	A	Y			
		4-005	2ND LEVEL LAUNDRY	A	Y	1		
		4-006	3RD LEVEL LAUNDRY	A	Y	1		
		4-007	APARTMENT #66	A	Y	1	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
50	WELL 1	2	WELL 1	A				
53049	ATMOSPHERIC STORAGE							
53051	PRESSURE STORAGE							
61	WELL 2	2	WELL 2	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
BARKLEY, DARRELL	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR CONDITIONAL	12/31/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470071	EAST WINDSOR HOUSING AUTHORITY			C	94	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1A PARK HILL			84				

Towns Served:

Contact Information

Name				Organization			Job Title		
East Windsor Housing Authority									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Emergency Contact						Emergency Contact		CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-623-8929									

Contact Role(s): **Owner**

Name				Organization			Job Title		
Ms. Linda Collins				East Windsor Housing Authority			Irector		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1 A Park Hill						Broad Brook		CT	06016
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-623-8467			860-623-8554				ewhaed@gmail.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		100 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19			
Orthophosphate (1044)		20 routine (RT) per six months		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete	
	1/1/19 - 6/30/19			
	7/1/19 - 12/31/19			
Asbestos (1094)		2 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		Complete	
Total Coliform (3100)		100 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19			
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			
	Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BUDGET R-A-C,B/F,WL (3065)	10/1/18 - 12/31/18	11/1-11/30	Complete	
	1/1/19 - 3/31/19	2/1-2/28	Complete	
	4/1/19 - 6/30/19	5/1-5/31		
	7/1/19 - 9/30/19	8/1-8/31		
ELSWRTH,26 RYE,BDBRK (3067)	10/1/18 - 12/31/18	11/1-11/30	Complete	
	1/1/19 - 3/31/19	2/1-2/28	Complete	
	4/1/19 - 6/30/19	5/1-5/31		
	7/1/19 - 9/30/19	8/1-8/31		
1275 JOHN FITCH, S WNSDR (3081)	10/1/18 - 12/31/18	11/1-11/30	Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
201 LAKE ST, VERNON (3083)	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
29 S MAIN, S WINDSOR (3084)	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
678 OLD POST RD, TOLLAND (3085)	7/1/19 - 9/30/19	8/1-8/31	
	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
TOWN HALL, ELLINGTON (6056)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
	10/1/18 - 12/31/18	11/1-11/30	Complete
CLUB HOUSE (MW001)	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
Lead And Copper (PBCU)	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
	10/1/18 - 12/31/18	11/1-11/30	Complete
60 routine (RT) per six months			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		
	7/1/19 - 12/31/19		
Physical Parameters (PPS)		100 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		100 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water Quality Parameters (WQPD)		20 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete	
	1/1/19 - 6/30/19			
	7/1/19 - 12/31/19			

Water System Facility: **ENTRY POINT - ROCKVILLE WTP (WSF ID: 00700)**

Orthophosphate (1044)		1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - ROCKVILLE WTP (3)	11/2/18 - 11/15/18		Complete	
	11/16/18 - 11/29/18		Complete	
	11/30/18 - 12/13/18		Complete	
	12/14/18 - 12/27/18		Complete	
	12/28/18 - 1/10/19		Complete	
	1/11/19 - 1/24/19		Complete	
	1/25/19 - 2/7/19		Complete	
	2/8/19 - 2/21/19		Complete	
	2/22/19 - 3/7/19		Complete	
	3/8/19 - 3/21/19		Complete	
	3/22/19 - 4/4/19		Complete	
	4/5/19 - 4/18/19			

pH (1925)		1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - ROCKVILLE WTP (3)	11/2/18 - 11/15/18		Complete	
	11/16/18 - 11/29/18		Complete	
	11/30/18 - 12/13/18		Complete	
	12/14/18 - 12/27/18		Complete	
	12/28/18 - 1/10/19		Complete	
	1/11/19 - 1/24/19		Complete	
	1/25/19 - 2/7/19		Complete	
	2/8/19 - 2/21/19		Complete	
	2/22/19 - 3/7/19		Complete	
	3/8/19 - 3/21/19		Complete	
	3/22/19 - 4/4/19		Complete	
	4/5/19 - 4/18/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - ROCKVILLE WTP (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: ENTRY POINT - HUNT WELLFIELD (WSF ID: 00701)

Orthophosphate (1044)		1 routine (RT) per two weeks	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-HUNT WELLFIELD (3)	11/2/18 - 11/15/18		Complete
	11/16/18 - 11/29/18		Complete
	11/30/18 - 12/13/18		Complete
	12/14/18 - 12/27/18		Complete
	12/28/18 - 1/10/19		Complete
	1/11/19 - 1/24/19		Complete
	1/25/19 - 2/7/19		Complete
	2/8/19 - 2/21/19		Complete
	2/22/19 - 3/7/19		Complete
	3/8/19 - 3/21/19		Complete
	3/22/19 - 4/4/19		Complete
	4/5/19 - 4/18/19		
pH (1925)		1 routine (RT) per two weeks	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - HUNT WELLFIELD (WSF ID: 00701)

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	11/2/18 - 11/15/18		Complete
	11/16/18 - 11/29/18		Complete
	11/30/18 - 12/13/18		Complete
	12/14/18 - 12/27/18		Complete
	12/28/18 - 1/10/19		Complete
	1/11/19 - 1/24/19		Complete
	1/25/19 - 2/7/19		Complete
	2/8/19 - 2/21/19		Complete
	2/22/19 - 3/7/19		Complete
	3/8/19 - 3/21/19		Complete
	3/22/19 - 4/4/19		Complete
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - HUNT WELLFIELD (WSF ID: 00701)

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-HUNT WELLFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Water System Facility: ENTRY POINT - POWDER HOLLOW WELL FIELD (WSF ID: 00702)

pH (1925)	1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	11/2/18 - 11/15/18		Complete
	11/16/18 - 11/29/18		Complete
	11/30/18 - 12/13/18		Complete
	12/14/18 - 12/27/18		Complete
	12/28/18 - 1/10/19		Complete
	1/11/19 - 1/24/19		Complete
	1/25/19 - 2/7/19		Complete
	2/8/19 - 2/21/19		Complete
	2/22/19 - 3/7/19		Complete
	3/8/19 - 3/21/19		Complete
	3/22/19 - 4/4/19		Complete
	4/5/19 - 4/18/19		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - POWDER HOLLOW WELL FIELD (WSF ID: 00702)

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Water System Facility: ENTRY POINT - SPRING LOTS WELLFIELD (WSF ID: 00703)

pH (1925)	1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	11/2/18 - 11/15/18		Complete
	11/16/18 - 11/29/18		Complete
	11/30/18 - 12/13/18		Complete
	12/14/18 - 12/27/18		Complete
	12/28/18 - 1/10/19		Complete
	1/11/19 - 1/24/19		Complete
	1/25/19 - 2/7/19		Complete
	2/8/19 - 2/21/19		Complete
	2/22/19 - 3/7/19		Complete
	3/8/19 - 3/21/19		Complete
	3/22/19 - 4/4/19		Complete
	4/5/19 - 4/18/19		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - VERNON WELL 1 (WSF ID: 00705)

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 1 (3)	11/2/18 - 11/15/18		Out of Service
	11/16/18 - 11/29/18		Out of Service
	11/30/18 - 12/13/18		Out of Service
	12/14/18 - 12/27/18		Out of Service
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 1 (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 1 (3)	1/1/18 - 12/31/18		Out of Service
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - VERNON WELL 1 (WSF ID: 00705)

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 1 (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Water System Facility: ENTRY POINT - VERNON WELL 2 (WSF ID: 00706)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	1/1/18 - 12/31/18		Out of Service
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

pH (1925)	1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	11/2/18 - 11/15/18		Out of Service
	11/16/18 - 11/29/18		Out of Service
	11/30/18 - 12/13/18		Out of Service
	12/14/18 - 12/27/18		Out of Service
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		

Net Gross Alpha (4000)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Uranium (4006)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Combined Radium-226/228 (4010)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - VERNON WELL 2 (WSF ID: 00706)

Combined Radium-226/228 (4010)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 2 (3)	1/1/18 - 12/31/18		Out of Service
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: ENTRY POINT - VERNON WELL 4 (WSF ID: 00708)

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 4 (3)	11/2/18 - 11/15/18		Out of Service
	11/16/18 - 11/29/18		Out of Service
	11/30/18 - 12/13/18		Out of Service
	12/14/18 - 12/27/18		Out of Service
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - VERNON WELL 4 (WSF ID: 00708)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 4 (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 4 (3)	1/1/18 - 12/31/18		Out of Service
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 4 (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Water System Facility: ENTRY POINT - VERNON WELL 5 (WSF ID: 00709)

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 5 (3)	11/2/18 - 11/15/18		Out of Service
	11/16/18 - 11/29/18		Out of Service
	11/30/18 - 12/13/18		Out of Service
	12/14/18 - 12/27/18		Out of Service
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Benzo (a) Pyrene (2306)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-VERNON WELL 5 (3)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - VERNON WELL 5 (WSF ID: 00709)

Benzo (a) Pyrene (2306)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Water System Facility: ENTRY POINT - WOODLAND PARK WELL (WSF ID: 00713)			
pH (1925)		1 routine (RT) per two weeks	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	11/2/18 - 11/15/18		Out of Service
	11/16/18 - 11/29/18		Out of Service
	11/30/18 - 12/13/18		Out of Service
	12/14/18 - 12/27/18		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						36,248	

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - WOODLAND PARK WELL (WSF ID: 00713)

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Tritium (4102)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Strontium-90 (4174)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - WOODLAND PARK WELL (WSF ID: 00713)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/18 - 12/31/18		Out of Service
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: ENTRY POINT - PINE KNOB WELL (WSF ID: 00714)

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINE KNOB WELL (3)	11/2/18 - 11/15/18		Out of Service
	11/16/18 - 11/29/18		Out of Service
	11/30/18 - 12/13/18		Out of Service
	12/14/18 - 12/27/18		Out of Service
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINE KNOB WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINE KNOB WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - PINE KNOB WELL (WSF ID: 00714)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Water System Facility: ENTRY POINT - WEST SUFFIELD WELL (WSF ID: 00715)			
pH (1925)		1 routine (RT) per two weeks	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	11/2/18 - 11/15/18		
	11/16/18 - 11/29/18		
	11/30/18 - 12/13/18		
	12/14/18 - 12/27/18		
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - WEST SUFFIELD WELL (WSF ID: 00715)

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Water System Facility: ENTRY POINT - MAPLETON STATION (WSF ID: 00716)

pH (1925)		1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-MAPLETON STATION (3)	11/2/18 - 11/15/18		Out of Service	
	11/16/18 - 11/29/18		Out of Service	
	11/30/18 - 12/13/18		Out of Service	
	12/14/18 - 12/27/18		Out of Service	
	12/28/18 - 1/10/19			
	1/11/19 - 1/24/19			
	1/25/19 - 2/7/19			
	2/8/19 - 2/21/19			
	2/22/19 - 3/7/19			
	3/8/19 - 3/21/19			
	3/22/19 - 4/4/19			
	4/5/19 - 4/18/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - MAPLETON STATION (WSF ID: 00716)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAPLETON STATION (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAPLETON STATION (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAPLETON STATION (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAPLETON STATION (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAPLETON STATION (3)	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAPLETON STATION (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAPLETON STATION (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Water System Facility: ENTRY POINT - O'BREADY (WSF ID: 00719)

pH (1925)		1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-O'BREADY (3)	11/2/18 - 11/15/18		Out of Service	
	11/16/18 - 11/29/18		Out of Service	
	11/30/18 - 12/13/18		Out of Service	
	12/14/18 - 12/27/18		Out of Service	
	12/28/18 - 1/10/19			
	1/11/19 - 1/24/19			
	1/25/19 - 2/7/19			
	2/8/19 - 2/21/19			
	2/22/19 - 3/7/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - O'BREADY (WSF ID: 00719)

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-O'BREADY (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-O'BREADY (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-O'BREADY (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-O'BREADY (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-O'BREADY (3)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-O'BREADY (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-O'BREADY (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Water System Facility: ENTRY POINT -ELLINGTON ACRES TREATMT PLT (WSF ID: 00721)			
Nitrate (1040)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	10/1/18 - 12/31/18		
	1/1/19 - 3/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT -ELLINGTON ACRES TREATMT PLT (WSF ID: 00721)

Nitrate (1040)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Nitrite (1041)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	1/1/18 - 12/31/18		
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	11/2/18 - 11/15/18		
	11/16/18 - 11/29/18		
	11/30/18 - 12/13/18		
	12/14/18 - 12/27/18		
	12/28/18 - 1/10/19		
	1/11/19 - 1/24/19		
	1/25/19 - 2/7/19		
	2/8/19 - 2/21/19		
	2/22/19 - 3/7/19		
	3/8/19 - 3/21/19		
	3/22/19 - 4/4/19		
	4/5/19 - 4/18/19		
Net Gross Alpha (4000)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	1/1/17 - 12/31/25		
Uranium (4006)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	1/1/17 - 12/31/25		
Combined Radium-226/228 (4010)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	1/1/17 - 12/31/25		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT -ELLINGTON ACRES TREATMT PLT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT - ELLINGTON ACRES TREATMT PLT (WSF ID: 00721)

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ELLINGTON ACRES TREATMT PLT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Water System Facility: SPRING LOTS WELL 3 (WSF ID: 1245)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL SPRING LOTS 3 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: SPRING LOTS WELL 5 (WSF ID: 1247)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING LOTS WELL 5 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: O'BREADY WELL (WSF ID: 1267)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
O'BREADY WELL (2)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: **O'BREADY WELL (WSF ID: 1267)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	2/1/19 - 2/28/19		Out of Service	
	3/1/19 - 3/31/19		Out of Service	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **HUNT WELL 5 (WSF ID: 1278)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
HUNT WELL 5 (2)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19			
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **HUNT WELL 6 (WSF ID: 1279)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
HUNT WELL 6 (2)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19			
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: HUNT WELL 6 (WSF ID: 1279)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/19 - 10/31/19		

Water System Facility: HUNT WELL 8 (WSF ID: 1281)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 8 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: HUNT WELL 9 (WSF ID: 1282)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 9 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: HUNT WELL 10 (WSF ID: 1937)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 10 (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: HUNT WELL 10 (WSF ID: 1937)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	3/1/19 - 3/31/19			
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: SHENIPSIT LAKE (WSF ID: 2077)

Total Alkalinity (1927)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
SHENIPSIT LAKE (1)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Total Organic Carbon (2920)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
SHENIPSIT LAKE (1)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: **SHENIPSIT LAKE (WSF ID: 2077)**

Total Coliform (3100)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SHENIPSIT LAKE (1)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SHENIPSIT LAKE (1)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SHENIPSIT LAKE (1)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Surface Water Pesticides (RSOC)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SHENIPSIT LAKE (1)	1/1/18 - 12/31/18		Complete	
	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			

Water System Facility: **MAPLETON AVE WELL 2 (WSF ID: 4)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
MAPLETON AVE WELL 2 (2)	11/1/18 - 11/30/18		Out of Service	
	12/1/18 - 12/31/18		Out of Service	
	1/1/19 - 1/31/19		Out of Service	
	2/1/19 - 2/28/19		Out of Service	
	3/1/19 - 3/31/19		Out of Service	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **SPRING LOTS WELL 7 (WSF ID: 47835)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248

Towns Served:

Monitoring Requirements

Water System Facility: **SPRING LOTS WELL 7 (WSF ID: 47835)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SPRING LOTS WELL 7 (2)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19			
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **SPRING LOTS WELL 8 (WSF ID: 52905)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SPRING LOTS WELL 8 (2)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19			
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **SPRING LOTS WELL 9 (WSF ID: 54961)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SPRING LOTS WELL 9 (2)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19			
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Monitoring Requirements

Water System Facility: **SPRING LOTS WELL 9 (WSF ID: 54961)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **PRESTON WELL #1 (WSF ID: 56751)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PRESTON WELL #1 (2)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ELLINGTON ACRES WELL #3 (WSF ID: 66)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELLINGTON ACRES WELL #3 (2)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ELLINGTON ACRES WELL #2 (WSF ID: 67)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELLINGTON ACRES WELL #2 (2)	11/1/18 - 11/30/18		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						36,248	

Towns Served:

Monitoring Requirements

Water System Facility: ELLINGTON ACRES WELL #2 (WSF ID: 67)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: ELLINGTON ACRES WELL #1 (WSF ID: 68)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - ROCKVILLE WTP (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 0.7 MG/L	Daily
Start Date: 5/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					36,248

Towns Served:

Water System Facility: ENTRY POINT - ROCKVILLE WTP (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 0.7 MG/L	Daily
Start Date: 5/1/2017			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 5/1/2017			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		
	12/1/2018 - 12/31/2018		
	1/1/2019 - 1/31/2019		
	2/1/2019 - 2/28/2019		
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3.0 MG/L	2
Start Date: 5/1/2017			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		
	12/1/2018 - 12/31/2018		
	1/1/2019 - 1/31/2019		
	2/1/2019 - 2/28/2019		
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - HUNT WELLFIELD (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		
	12/1/2018 - 12/31/2018		
	1/1/2019 - 1/31/2019		
	2/1/2019 - 2/28/2019		
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						36,248	

Towns Served:

Water System Facility: ENTRY POINT - HUNT WELLFIELD (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3.0 MG/L	2
Start Date: 1/1/2006			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Water System Facility: ENTRY POINT - POWDER HOLLOW WELL FIELD (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	30
Start Date: 6/1/2015			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

Water System Facility: ENTRY POINT - SPRING LOTS WELLFIELD (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2008			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	Y Y
		12/1/2018 - 12/31/2018	Y Y
		1/1/2019 - 1/31/2019	Y Y
		2/1/2019 - 2/28/2019	Y Y
		3/1/2019 - 3/31/2019	Y Y
		4/1/2019 - 4/30/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility: ENTRY POINT - SPRING LOTS WELLFIELD (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 6/1/2008	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - VERNON WELL 1 (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 10/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - VERNON WELL 2 (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility: ENTRY POINT - VERNON WELL 2 (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 10/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - VERNON WELL 4 (WSFID: 00708)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 6/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility: ENTRY POINT - VERNON WELL 5 (WSFID: 00709)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - WOODLAND PARK WELL (WSFID: 00713)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - PINE KNOB WELL (WSFID: 00714)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 10/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - MAPLETON STATION (WSFID: 00716)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility: ENTRY POINT - MAPLETON STATION (WSFID: 00716)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline	3/1/2019 - 3/31/2019	n/a
		4/1/2019 - 4/30/2019	Y

Analyte	Monitoring Requirement (Summary Type)		Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)		Average: 1.2 MG/L	Daily
Start Date:	6/1/2005	Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
	Offline	11/1/2018 - 11/30/2018	n/a	Y
	Offline	12/1/2018 - 12/31/2018	n/a	Y
	Offline	1/1/2019 - 1/31/2019	n/a	Y
	Offline	2/1/2019 - 2/28/2019	n/a	Y
	Offline	3/1/2019 - 3/31/2019	n/a	Y
		4/1/2019 - 4/30/2019		

Water System Facility: ENTRY POINT - O'BREADY (WSFID: 00719)

Analyte	Monitoring Requirement (Summary Type)		Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)		Minimum: 0.2 MG/L	Daily
Start Date:	1/1/2004	Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
	Offline	11/1/2018 - 11/30/2018	n/a	Y
	Offline	12/1/2018 - 12/31/2018	n/a	Y
	Offline	1/1/2019 - 1/31/2019	n/a	Y
	Offline	2/1/2019 - 2/28/2019	n/a	Y
	Offline	3/1/2019 - 3/31/2019	n/a	Y
		4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily	
Start Date: 1/1/2004				
	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	Offline	11/1/2018 - 11/30/2018	n/a	Y
	Offline	12/1/2018 - 12/31/2018	n/a	Y
	Offline	1/1/2019 - 1/31/2019	n/a	Y
	Offline	2/1/2019 - 2/28/2019	n/a	Y
	Offline	3/1/2019 - 3/31/2019	n/a	Y
		4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM	C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					36,248
					Agricultural

Towns Served:

Water System Facility: ENTRY POINT - ELLINGTON ACRES TREATMT PLT (WSFID: 00721)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.4 MG/L	Daily
Start Date: 3/1/2010			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline	11/1/2018 - 11/30/2018	n/a
	Offline	12/1/2018 - 12/31/2018	n/a
	Offline	1/1/2019 - 1/31/2019	n/a
	Offline	2/1/2019 - 2/28/2019	n/a
	Offline	3/1/2019 - 3/31/2019	n/a
		4/1/2019 - 4/30/2019	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 8/1/2009			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline	11/1/2018 - 11/30/2018	n/a
	Offline	12/1/2018 - 12/31/2018	n/a
	Offline	1/1/2019 - 1/31/2019	n/a
	Offline	2/1/2019 - 2/28/2019	n/a
	Offline	3/1/2019 - 3/31/2019	n/a
		4/1/2019 - 4/30/2019	

Water System Facility: ENTRY POINT - PRESTON WELL #1 (WSFID: 00722)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: .2 MG/L	Daily
Start Date: 12/1/2010			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline	11/1/2018 - 11/30/2018	n/a
	Offline	12/1/2018 - 12/31/2018	n/a
	Offline	1/1/2019 - 1/31/2019	n/a
	Offline	2/1/2019 - 2/28/2019	n/a
	Offline	3/1/2019 - 3/31/2019	n/a
		4/1/2019 - 4/30/2019	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	Daily
Start Date: 12/1/2010			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	Offline	11/1/2018 - 11/30/2018	n/a
	Offline	12/1/2018 - 12/31/2018	n/a
	Offline	1/1/2019 - 1/31/2019	n/a
	Offline	2/1/2019 - 2/28/2019	n/a
	Offline	3/1/2019 - 3/31/2019	n/a
		4/1/2019 - 4/30/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						36,248	

Towns Served:

Water System Facility: ROCKVILLE WATER TREATMENT PLANT (WSFID: 60576)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2017			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
11/1/2018 - 11/30/2018	Y	Y	
12/1/2018 - 12/31/2018	Y	Y	
1/1/2019 - 1/31/2019	Y	Y	
2/1/2019 - 2/28/2019	Y	Y	
3/1/2019 - 3/31/2019	Y	Y	
4/1/2019 - 4/30/2019			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 5/1/2017			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
11/1/2018 - 11/30/2018	Y	Y	
12/1/2018 - 12/31/2018	Y	Y	
1/1/2019 - 1/31/2019	Y	Y	
2/1/2019 - 2/28/2019	Y	Y	
3/1/2019 - 3/31/2019	Y	Y	
4/1/2019 - 4/30/2019			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 5/1/2017			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
11/1/2018 - 11/30/2018	Y	Y	
12/1/2018 - 12/31/2018	Y	Y	
1/1/2019 - 1/31/2019	Y	Y	
2/1/2019 - 2/28/2019	Y	Y	
3/1/2019 - 3/31/2019	Y	Y	
4/1/2019 - 4/30/2019			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	3/14/2019
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CAP - ADDRESS DEFICIENCY	9/30/2019	
CAP - ADDRESS DEFICIENCY	9/30/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Organic Chemicals M&R Violation	1/1/14 - 12/31/16	3	6/7/2018		6/17/2018	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Radionuclides - Gross Alpha, Combined Ra M&R Violati	1/1/14 - 12/31/16	3	6/7/2018		6/17/2018	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	RAW ENTRY POINT - WNDSR LKS CAISN WELLS	2	RAW ENRTY POINT	A				
00600	DISTRIBUTION SYSTEM	3050	RADISSN HTL 5/91,ENF	A	Y			
		3051	PRUDNCE CRANDL S,ENF	A	Y			
		3052	DUNK DON,651 ENF	A	Y		Y	
		3053	ENF AUTO TRM,941 ENF	A	Y			
		3054	ENF SAFETY CMP,ELM S	A	Y			
		3055	MARSHALLS 10 HAZ,ENF	A	Y			
		3056	CVS, 90 MAIN S,WL	A	Y			
		3057	AHLSTROM,1 ELM, WL	A	Y			
		3058	DARY MRT,245 ELLA,WL	A	Y			
		3059	SUF BOOSTER, SUF ST	A	Y			
		3060	CT WATER CO, EW	A	Y		Y	
		3061	CVS, 152 MTN RD,SUF	A	Y			
		3062	SWPD, 151 SND HL,SW	A	Y			
		3063	SUNDAE,845 SULL A,SW	A	Y			
		3064	(30643) CRESCENT LAK	A	Y			
		30643	31 LAKE DR, ENFIELD	A	Y			
		3065	BUDGET R-A-C,B/F,WL	A	Y			Y
		3066	1 BRIDL PTH LN,RH,VN	A	Y			
		3067	ELSWRTH,26 RYE,BDBRK	A	Y			Y
		3069	ENFIELD BOOSTER STA	A			Y	
		30801	60 ELM ST, VN	A		3		
		30802	55 TOLLAND GREN	A		3		
		30803	69 MOUNTAIN ST, ROCK	A		1		
		30804	120 PROSPECT ST,ROCK	A		3		
		30805	371 ELM ST,WIN LOCKS	A		N		
		30806	46 CENTER ST,WN LCKS	I		3		
		30807	71 SUFFIELD ST, WL	A		3		
		30808	25 OAK ST, SW	I		N		
		30809	107 RIVER RD, WL	A		N		
		3081	1275 JOHN FITCH, S W	A				Y
		30810	1 AYERSHIRE CT, SFD	A		N		
		30811	1680 MAPLETN AVE,SFD	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		30812	146 E GRAYLING, SF	A		2		
		30813	39 ARLINGTON RD,WL	A		3		
		30814	92 BRIAN RD, STH WIN	A		3		
		30815	3D SPRING CT,BRD BRK	I		N		
		30816	144 S CENTER ST, WL	A		3		
		30817	11 FIRST AVE, ENFLD	A		3		
		30818	36 VIRGINIA AVE,ENFD	A		3		
		30819	8 CIDERMILL RD. TOLL	A		3		
		3082	51 TOLLAND GRN, TOLL	A				Y
		30820	3 STONE STREET, ROCK	A		3		
		30821	75 GRAHAM RD. BB	A		1		
		30822	103 RIVER RD. WL	A		3		
		30823	241 N GRAND ST. WS	I		3		
		30824	46 TROMBLEY RD. EW	I		3		
		30825	144 E GRAYLING, SFD	A		2		
		30826	55 GRAHAM RD. BB	A		1		
		30827	21 FIRST AVE, ENF	A		1		
		30828	29 MARION ST. WL	A		3		
		30829	3A PASCO DR. EW	I		N		
		3083	201 LAKE ST, VERNON	A				Y
		30830	150 BERNADINO ENF	A		3		
		30831	15 NIEDERWERFER SW	A		2		
		30832	87 MEADOWLARK, VN	A		N		
		30833	48 TROMBLEY RD, EW	A		3		
		30834	26 PINNEY ST, ELL	A		N		
		30835	56 MIDDLE RD, ELL	A		3		
		30836	1 ELEANOR RD. ENF	A		3		
		30837	36 WHITON ST, ENF	I		3		
		30838	33 ST THOMAS ST, ENF	A		3		
		30839	85 OLD TOWN RD, VN	A		N		
		3084	29 S MAIN, S WINDSOR	A				Y
		30840	17 FIRST AVE, ENF	A		1		
		30841	16 ROBERT RD, ROCK	A		3		
		30842	1 SHARREN LN, ENF	A		3		
		30843	36 COOLIDGE ST, WL	A		3		
		30844	17 WASHINGTN AV, EN	I		N		
		30845	16 COOLIDGE ST, WL	I		3		
		30846	13 RIVERA DR, ENF	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		30847	5 HATHAWAY AV, EN	A		3		
		30848	22 BROADLEAF LN, EN	A		3		
		30849	96 DIBBLE HOLLOW, WL	I		N		
		3085	678 OLD POST RD, TOL	A				Y
		30850	49 LAUREL CIRCLE, EW	A		N		
		30851	47 WINKLER RD, EW	A		3		
		30852	17 KENT LN, SW	A		3		
		30853	41 WOODLAND TER SF	I		3		
		30854	154 ORCHARD ST, ELL	I		N		
		30855	34 GORDON AVE, ENF	A		3		
		30856	8A PASCO DR, EW	I		N		
		30857	142 GROVE ST, VN	I		N		
		30858	105 GROVE ST, VN	A		3		
		30859	44 WEST RD, SW	A		N		
		30860	8 MAIN ST, WL	I		N		
		30861	23 PEARL ST, WL	A		3		
		30862	53 NORTON RD, EW	A	Y	1		
		30863	2 BROCKWAY RD, ELL	A	Y	1		
		30864	8 GRANT RD, ELL	A	Y	1		
		30865	10 GRANT RD, ELL	A	Y	1		
		30866	57 HAYES AVE, ELL	A	Y	1		
		30867	119 PINNEY ST, ELL	A	Y	1		
		30868	123 PINNEY ST, ELL	A	Y	1		
		30869	7 RIDGEVIEW DR, ELL	A	Y	1		
		30870	54 UPR BTCHR RD, ELL	A	Y	1		
		30871	26 WINDMILL RD, ELL	A	Y	1		
		30872	35 WINDMILL RD, ELL	A	Y	1		
		30873	52 WINDMILL RD, ELL	A	Y	1		
		30874	3 BOUVIER ST, ENF	A	Y	1		
		30875	45 BRIDGE LN, ENF	A	Y	1		
		30876	12 CARTIER RD, ENF	A	Y	1		
		30877	14 CARTIER RD, ENF	A	Y	1		
		30878	15 CARTIER RD, ENF	A	Y	1		
		30879	17 CARTIER RD, ENF	A	Y	1		
		30880	19 CARTIER RD, ENF	A	Y	1		
		30881	20 CARTIER RD, ENF	A	Y	1		
		30882	15 CIRCLE DR, ENF	A	Y	1		
		30883	10 CONN AVE A, ENF	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		30884	86 COTTAGE RD, ENF	A	Y	1		
		30885	177 COTTAGE RD, ENF	A	Y	1		
		30886	179 COTTAGE RD, ENF	A	Y	1		
		30887	24 DANNUNZIO AV, ENF	A	Y	1		
		30888	2 DEBBIE LN, ENF	A	Y	1		
		30889	2 DOVER RD, ENF	A	Y	1		
		30890	4 DOVER RD, ENF	A	Y	1		
		30891	6 DOVER RD, ENF	A	Y	1		
		30892	8 DOVER RD, ENF	A	Y	1		
		30893	3 E FOREST DR, ENF	A	Y	1		
		30894	4 E FOREST DR, ENF	A	Y	1		
		30895	5 E FOREST DR, ENF	A	Y	1		
		30896	6 E FOREST DR, ENF	A	Y	1		
		30897	7 E FOREST DR, ENF	A	Y	1		
		30898	8 E FOREST DR, ENF	A	Y	1		
		30899	9 E FOREST DR, ENF	A	Y	1		
		30900	10 E FOREST DR, ENF	A	Y	1		
		30901	11 E FOREST DR, ENF	A	Y	1		
		30902	12 E FOREST DR, ENF	A	Y	1		
		30903	5 ELM AVE, ENF	A	Y	1		
		30904	222 ELM ST, ENF	A	Y	1		
		30905	1164 ENFIELD ST, ENF	A	Y	1		
		30906	1265 ENFIELD ST, ENF	A	Y	1		
		30907	1465 1/2 ENF ST, ENF	A	Y	1		
		30908	49 FAIRVIEW AVE, ENF	A	Y	1		
		30909	19 FALCON CREST, ENF	A	Y	1		
		30910	20 FALCON CREST, ENF	A	Y	1		
		30911	21 FALCON CREST, ENF	A	Y	1		
		30912	22 FALCON CREST, ENF	A	Y	1		
		30913	23 FALCON CREST, ENF	A	Y	1		
		30914	24 FALCON CREST, ENF	A	Y	1		
		30915	26 FALCON CREST, ENF	A	Y	1		
		30916	7 FIRST AVE, ENF	A	Y	1		
		30917	16 FIRST AVE, ENF	A	Y	1		
		30918	20 FIRST AVE, ENF	A	Y	1		
		30919	7 GAMMELLO AVE, ENF	A	Y	1		
		30920	2 HILLYER DR, ENF	A	Y	1		
		30921	8 HILLYER DR, ENF	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		30922	1 HOLLY LN, ENF	A	Y	1		
		30923	19 JONDOT DR, ENF	A	Y	1		
		30924	5 LEON ST, ENF	A	Y	1		
		30925	9 MARGARET ST, ENF	A	Y	1		
		30926	48 OAKWOOD ST, ENF	A	Y	1		
		30927	5 ABAR LN, SW	A	Y	1		
		30928	6 ABAR LN, SW	A	Y	1		
		30929	14 ABAR LN, SW	A	Y	1		
		30930	15 ABAR LN, SW	A	Y	1		
		30931	20 ABAR LN, SW	A	Y	1		
		30932	21 ABAR LN, SW	A	Y	1		
		30933	27 ABAR LN, SW	A	Y	1		
		30934	28 ABAR LM, SW	A	Y	1		
		30935	32 ABAR LN, SW	A	Y	1		
		30936	33 ABAR LN, SW	A	Y	1		
		30937	18 ALEXANDER PL, SW	A	Y	1		
		30938	24 ALEXANDER PL, SW	A	Y	1		
		30939	30 ALEXANDER PL, SW	A	Y	1		
		30940	33 ALEXANDER PL, SW	A	Y	1		
		30941	36 ALEXANDER PL, SW	A	Y	1		
		30942	39 ALEXANDER PL, SW	A	Y	1		
		30943	7 ANDREIS TRL, SW	A	Y	1		
		30944	11 ANDREIS TRL, SW	A	Y	1		
		30945	19 ANDREIS TRL, SW	A	Y	1		
		30946	20 ANDREIS TRL, SW	A	Y	1		
		30947	30 ANDREIS TRL, SW	A	Y	1		
		30948	31 ANDREIS TRL, SW	A	Y	1		
		30949	38 ANDREIS TRL, SW	A	Y	1		
		3095	BRADLEY BOOSTER,WL	A	Y			
		30950	43 ANDREIS TRL, SW	A	Y	1		
		30951	46 ANDREIS TRL, SW	A	Y	1		
		30952	53 ANDREIS TRL, SW	A	Y	1		
		30953	54 ANDREIS TRL, SW	A	Y	1		
		30954	65 ANDREIS TRL, SW	A	Y	1		
		30955	73 ANDREIS TRL, SW	A	Y	1		
		30956	74 ANDREIS TRL, SW	A	Y	1		
		30957	79 ANDREIS TRL, SW	A	Y	1		
		30958	80 ANDREIS TRL, SW	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		30959	88 ANDREIS TRL, SW	A	Y	1		
		30960	93 ANDREIS TRL, SW	A	Y	1		
		30961	97 ANDREIS TRL, SW	A	Y	1		
		30962	98 ANDREIS TRL, SW	A	Y	1		
		30963	104 ANDREIS TRL, SW	A	Y	1		
		30964	105 ANDREIS TRL, SW	A	Y	1		
		30965	108 ANDREIS TRL, SW	A	Y	1		
		30966	354 AVERY ST, SW	A	Y	1		
		30967	571 AVERY ST, SW	A	Y	1		
		30968	10 BENJAMIN WAY, SW	A	Y	1		
		30969	20 BENJAMIN WAY, SW	A	Y	1		
		3097	BRADLEY FIELD TANKS	A	Y			
		30970	25 BENJAMIN WAY, SW	A	Y	1		
		30971	BRADLEY TANK 1, WL	A	Y			
		30972	BRADLEY TANK 2, WL	A	Y			
		30973	BRADLEY TANK 3, WL	A	Y			
		30974	40 BENJAMIN WAY, SW	A	Y	1		
		30975	29 BOURBON ST, SW	A	Y	1		
		30976	32 BOURBON ST, SW	A	Y	1		
		30977	37 BOURBON ST, SW	A	Y	1		
		30978	45 BOURBON ST, SW	A	Y	1		
		30979	50 BOURBON ST, SW	A	Y	1		
		30980	51 BOURBON ST, SW	A	Y	1		
		30981	57 BOURBON ST, SW	A	Y	1		
		30982	60 BOURBNO ST, SW	A	Y	1		
		30983	67 BOURBON ST, SW	A	Y	1		
		30984	68 BOURBON ST, SW	A	Y	1		
		30985	73 BOURBON ST, SW	A	Y	1		
		30986	76 BOURBON ST, SW	A	Y	1		
		30987	84 BOURBON ST, SW	A	Y	1		
		30988	85 BOURBON ST, SW	A	Y	1		
		30989	91 BOURBON ST, SW	A	Y	1		
		30990	94 BOURBON ST, SW	A	Y	1		
		30991	106 BOURBON ST, SW	A	Y	1		
		3099-1	21 ROSS WAY	A	Y			
		30992	111 BOURBON ST, SW	A	Y	1		
		3099-2	16 CHERRY ST	A	Y			
		30993	166 BOURBON ST, SW	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		3099-3	23 PEARL STREET	A	Y			
		30994	171 BOURBON ST, SW	A	Y	1		
		3099-4	36 WHITON STREET	A	Y			
		30995	174 BOURBON ST, SW	A	Y	1		
		3099-5	8 MICHELLE DRIVE	A	Y			
		30996	184 BOURBON ST, SW	A	Y	1		
		3099-6	81 COLONIAL DRIVE	A	Y			
		30997	191 BOURBON ST, SW	A	Y	1		
		30998	199 BOURBON ST, SW	A	Y	1		
		30999	200 BOURBON ST, SW	A	Y	1		
		31000	203 BOURBON ST, SW	A	Y	1		
		31001	206 BOURBON ST, SW	A	Y	1		
		31002	10 BRMBLEBRAE RD, SW	A	Y	1		
		31003	20 BRMBLEBRAE RD, SW	A	Y	1		
		31004	28 BRMBLEBRAE RD, SW	A	Y	1		
		31005	41 BRMBLEBRAE RD, SW	A	Y	1		
		31006	53 BRMBLEBRAE RD, SW	A	Y	1		
		31007	56 BRMBLEBRAE RD, SW	A	Y	1		
		31008	11 BRIDLEWOOD RD, SW	A	Y	1		
		31009	32 BRIDLEWOOD RD, SW	A	Y	1		
		31010	41 BRIDLEWOOD RD, SW	A	Y	1		
		31011	44 BRIDLEWOOD RD, SW	A	Y	1		
		31012	56 BRIDLEWOOD RD, SW	A		1		
		31013	15 CADBURY LN, SW	A	Y	1		
		31014	19 CADBURY LN, SW	A	Y	1		
		31015	20 CADBURY LN, SW	A	Y	1		
		31016	27 CADBURY LN, SW	A	Y	1		
		31017	CTWC - NO WESTERN	A	Y			
		31018	35 CADBURY LN, SW	A	Y	1		
		31019	42 CADBURY LN, SW	A	Y	1		
		31020	45 CADBURY LN, SW	A	Y	1		
		31021	50 CADBURY LN, SW	A	Y	1		
		31022	53 CADBURY LN, SW	A	Y	1		
		31023	59 CADBURY LN, SW	A	Y	1		
		31024	66 CADBURY LN, SW	A	Y	1		
		31025	71 CADBURY LN, SW	A	Y	1		
		31026	72 CADBURY LN, SW	A	Y	1		
		31027	75 CADBURY LN, SW	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31028	81 CADBURY LN, SW	A	Y	1		
		31029	88 CADBURY LN, SW	A	Y	1		
		31030	91 CADBURY LN, SW	A	Y	1		
		31031	100 CADBURY LN, SW	A	Y	1		
		31032	108 CADBURY LN, SW	A	Y	1		
		31033	111 CADBURY LN, SW	A	Y	1		
		31034	75 BRN DR HILL, SFD	A	Y	1		
		31035	160 BRN DR HILL, SFD	A	Y	1		
		31036	25 BARRY PL, SFD	A	Y	1		
		31037	30 BARRY PL, SFD	A	Y	1		
		31038	35 BARRY PL, SFD	A	Y	1		
		31039	40 BARRY PL, SFD	A	Y	1		
		31040	60 BARRY PL, SFD	A	Y	1		
		31041	65 BARRY PL, SFD	A	Y	1		
		31042	60 BROOKSIDE DR, SFD	A	Y	1		
		31043	65 BROOKSIDE DR, SFD	A	Y	1		
		31044	85 BROOKSIDE DR, SFD	A	Y	1		
		31045	90 BROOKSIDE DR, SFD	A	Y	1		
		31046	100 BROOKSIDE DR, SFD	A	Y	1		
		31047	24 COWAN ST, SFD	A	Y	1		
		31048	25 COWAN ST, SFD	A	Y	1		
		31049	26 COWAN ST, SFD	A	Y	1		
		31051	61 DIANE LN, SFD	A	Y	1		
		31052	75 DIANE LN, SFD	A	Y	1		
		31053	90 DIANE LN, SFD	A	Y	1		
		31054	93 DIANE LN, SFD	A	Y	1		
		31055	102 DIANE LN, SFD	A	Y	1		
		31056	103 DANE LN, SFD	A	Y	1		
		31057	113 DIANE LN, SFD	A	Y	1		
		31058	116 DIANE LN, SFD	A	Y	1		
		31059	126 DIANE LN, SFD	A	Y	1		
		31060	839 EAST ST N, SFD	A	Y	1		
		31061	230 FAIR HILL, SFD	A	Y	1		
		31062	20 HCKLBRRY HLW, SFD	A	Y	1		
		31063	21 HCKLBRRY HLW, SFD	A	Y	1		
		31064	31 HCKLBRRY HLW, SFD	A	Y	1		
		31065	40 HCKLBRRY HLW, SFD	A	Y	1		
		31066	30 JCQULINE CIR, SFD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31067	38 KILDEER LN, SFD	A	Y	1		
		31068	48 KILDEER LN, SFD	A	Y	1		
		31069	67 KILDEER LN, SFD	A	Y	1		
		31070	77 KILDEER LN, SFD	A	Y	1		
		31071	87 KILDEER LN, SFD	A	Y	1		
		31072	88 KILDEER LN, SFD	A	Y	1		
		31073	660 MPLETN AVE, SFD	A	Y	1		
		31074	1085 MPLETN AVE, SFD	A	Y	1		
		31075	1465 MPLETN AVE, SFD	A	Y	1		
		31076	190 MARBERN DR, SFD	A	Y	1		
		31077	945 MATHER ST, SFD	A	Y	1		
		31078	10 DOW ST, VN	A	Y	1		
		31079	9 ERIC CIR, VN	A	Y	1		
		31080	10 ERIC CIR, VN	A	Y	1		
		31081	12 ERIC CIR, VN	A	Y	1		
		31082	14 ERIC CIR, VN	A	Y	1		
		31083	16 ERIC CIR, VN	A	Y	1		
		31084	20 ERIC CIR, VN	A	Y	1		
		31085	23 ERIC CIR, VN	A	Y	1		
		31086	24 ERIC CIR, VN	A	Y	1		
		31087	26 ERIC CIR, VN	A	Y	1		
		31088	27 ERIC CIR, VN	A	Y	1		
		31089	13 HEATHER LN, VN	A	Y	1		
		31090	14 HEATHER LN, VN	A	Y	1		
		31091	52 KEVIN DR, VN	A	Y	1		
		31092	55 KEVIN DR, VN	A	Y	1		
		31093	56 KEVIN DR, VN	A	Y	1		
		31094	3 VASSAR ST, VN	A	Y	1		
		31095	7 VASSER ST, VN	A	Y	1		
		31096	9 VASSER ST, VN	A	Y	1		
		31097	35 WARREN AVE, VN	A	Y	1		
		31098	41 WARREN AVE, VN	A	Y	1		
		31099	47 WARREN AVE, VN	A	Y	1		
		31100	61 WARREN AVE, VN	A	Y	1		
		31101	94 WARREN AVE, VN	A	Y	1		
		31102	87 DEBORAH CIR, WL	A	Y	1		
		31103	91 DEBORAH CIR, WL	A	Y	1		
		31104	95 DEBORAH CIR, WL	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31105	99 DEBORAH CIR, WL	A	Y	1		
		31106	103 DEBORAH CIR, WL	A	Y	1		
		31107	516 ELM ST, WL	A	Y	1		
		31108	528 ELM ST, WL	A	Y	1		
		31109	10 JUBREY LN, WL	A	Y	1		
		31110	19 JUBREY LN, WL	A	Y	1		
		31111	20 LESLIE ST, WL	A	Y	1		
		31112	25 LESLIE ST, WL	A	Y	1		
		31113	29 LESLIE ST, WL	A	Y	1		
		31114	2 MAPLE AVE, WL	A	Y	1		
		31115	6 MAPLE AVE, WL	A	Y	1		
		31116	41 MARSHALL RD , WL	A	Y	1		
		31117	42 MARSHALL RD, WL	A	Y	1		
		31118	43 MARSHALL RD, WL	A	Y	1		
		31119	44 MARSHALL RD, WL	A	Y	1		
		31120	45 MARSHALL RD, WL	A	Y	1		
		31121	46 MARSHALL RD, WL	A	Y	1		
		31122	47 MARSHALL RD, WL	A	Y	1		
		31123	48 MARSHALL RD, WL	A	Y	1		
		31124	49 MARSHALL RD, WL	A	Y	1		
		31125	50 MARSHALL RD, WL	A	Y	1		
		31126	51 MARSHALL RD, WL	A	Y	1		
		31127	52 MARSHALL RD, WL	A	Y	1		
		31128	54 MARSHALL RD, WL	A	Y	1		
		31129	92 MICHELLE DR, WL	A	Y	1		
		31130	93 MICHELLE DR, WL	A	Y	1		
		31131	96 MICHELLE DR, WL	A	Y	1		
		31132	97 MICHELLE DR, WL	A	Y	1		
		31133	393 NORTH ST , WL	A	Y	1		
		31134	395 NORTH ST, WL	A	Y	1		
		31135	113 ORCH HILL DR, WL	A	Y	1		
		31136	114 ORCH HILL DR, WL	A	Y	1		
		31137	118 ORCH HILL DR, WL	A	Y	1		
		31138	126 ORCH HILL DR, WL	A	Y	1		
		31139	130 ORCH HILL DR, WL	A	Y	1		
		31140	91 PAUL DR, WL	A	Y	1		
		31141	201 ADAMS HLL WY, EW	A	Y	2		
		31142	202 ADAMS HLL WY, EW	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31143	203 ADAMS HLL WY, EW	A	Y	2		
		31144	218 ADAMS HLL WY, EW	A	Y	2		
		31145	221 ADAMS HLL WY, EW	A	Y	2		
		31146	227 ADAMS HLL WY, EW	A	Y	2		
		31147	228 ADAMS HLL WY, EW	A	Y	2		
		31148	238 ADAMS HLL WY, EW	A	Y	2		
		31149	16 CHASSE DR, EW	A	Y	2		
		31150	10 DANIEL DR, EW	A	Y	2		
		31151	13 DANIEL DR, EW	A	Y	2		
		31152	5 DAVID DR, EW	A	Y	2		
		31153	7 DAVID DR, EW	A	Y	2		
		31154	9 DAVID DR, EW	A	Y	2		
		31155	10 DAVID DR, EW	A	Y	2		
		31156	12 DAVID DR, EW	A	Y	2		
		31157	16 DAVID DR, EW	A	Y	2		
		31158	17 DAVID DR, EW	A	Y	2		
		31159	20 DAVID DR, EW	A	Y	2		
		31160	107 GRNWDS LN, EW	A	Y	2		
		31161	108 GRNWDS LN, EW	A	Y	2		
		31162	119 GRNWDS LN, EW	A	Y	2		
		31163	129 GRNWDS LN, EW	A	Y	2		
		31164	131 GRNWDS LN, EW	A	Y	2		
		31165	133 GRNWDS LN, EW	A	Y	2		
		31166	139 GRNWDS LN, EW	A	Y	2		
		31167	149 GRNWDS LN, EW	A	Y	2		
		31168	155 GRNWDS LN, EW	A	Y	2		
		31169	169 GRNWDS LN, EW	A	Y	2		
		31170	179 GRNWDS LN, EW	A	Y	2		
		31171	3 RVRVIEW DR A, EW	A	Y	2		
		31172	5 RVRVIEW DR A, EW	A	Y	2		
		31173	9 RVRVIEW DR A, EW	A	Y	2		
		31174	13 RVRVIEW DR A, EW	A	Y	2		
		31175	4 RVRVIEW DR B, EW	A	Y	2		
		31176	12 RVRVIEW DR B, EW	A	Y	2		
		31177	13 RVRVIEW DR B, EW	A	Y	2		
		31178	5 RVRVIEW DR C, EW	A	Y	2		
		31179	6 RVRVIEW DR C, EW	A	Y	2		
		31180	7 RVRVIEW DR C, EW	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31181	8 RVRVIEW DR C, EW	A	Y	2		
		31182	5 RVRVIEW DR D, EW	A	Y	2		
		31183	6 RVRVIEW DR D, EW	A	Y	2		
		31184	10 RVRVIEW DR D, EW	A	Y	2		
		31185	13 RVRVIEW DR D, EW	A	Y	2		
		31186	8 RVRVIEW DR E, EW	A	Y	2		
		31187	13 RVRVIEW DR E, EW	A	Y	2		
		31188	8 RVRVIEW DR G, EW	A	Y	2		
		31189	1 GRANT RD, ELL	A	Y	2		
		31190	20 BRKSIDE VLG, ENF	A	Y	2		
		31191	25 BRKSIDE VLG, ENF	A	Y	2		
		31192	29 BRKSIDE VLG, ENF	A	Y	2		
		31193	30 BRKSIDE VLG, ENF	A	Y	2		
		31194	31 BRKSIDE VLG, ENF	A	Y	2		
		31195	41 BRKSIDE VLG, ENF	A	Y	2		
		31196	42 BRKSIDE VLG, ENF	A	Y	2		
		31197	43 BRKSIDE VLG, ENF	A	Y	2		
		31198	42 CNDLWD CIR, ENF	A	Y	2		
		31199	12 CNDLWD DR, ENF	A	Y	2		
		31200	32 CNDLWD DR, ENF	A	Y	2		
		31201	72 HRTFRD AVE 1A, EN	A	Y	2		
		31202	1 THE LAURELS, ENF	A	Y	2		
		31203	2 THE LAURELS, ENF	A	Y	2		
		31204	3 THE LAURELS, ENF	A	Y	2		
		31205	4 THE LAURELS, ENF	A	Y	2		
		31206	5 THE LAURELS, ENF	A	Y	2		
		31207	6 THE LAURELS, ENF	A	Y	2		
		31208	7 THE LAURELS, ENF	A	Y	2		
		31209	8 THE LAURELS, ENF	A	Y	2		
		31210	11 THE LAURELS, ENF	A	Y	2		
		31211	12 THE LAURELS, ENF	A	Y	2		
		31212	15 THE LAURELS, ENF	A	Y	2		
		31213	18 THE LAURELS, ENF	A	Y	2		
		31214	20 THE LAURELS, ENF	A	Y	2		
		31215	21 THE LAURELS, ENF	A	Y	2		
		31216	22 THE LAURELS, ENF	A	Y	2		
		31217	24 THE LAURELS, ENF	A	Y	2		
		31218	26 THE LAURELS, ENF	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31219	32 THE LAURELS, ENF	A	Y	2		
		31220	35 THE LAURELS, ENF	A	Y	2		
		31221	37 THE LAURELS, ENF	A	Y	2		
		31222	43 THE LAURELS, ENF	A	Y	2		
		31223	47 THE LAURELS, ENF	A	Y	2		
		31224	49 THE LAURELS, ENF	A	Y	2		
		31225	57 THE LAURELS, ENF	A	Y	2		
		31226	59 THE LAURELS, ENF	A	Y	2		
		31227	62 THE LAURELS, ENF	A	Y	2		
		31228	64 THE LAURELS, ENF	A	Y	2		
		31229	65 THE LAURELS, ENF	A	Y	2		
		31230	71 THE LAURELS, ENF	A	Y	2		
		31231	72 THE LAURELS, ENF	A	Y	2		
		31232	73 THE LAURELS, ENF	A	Y	2		
		31233	76 THE LAURELS, ENF	A	Y	2		
		31234	78 THE LAURELS, ENF	A	Y	2		
		31235	81 THE LAURELS, ENF	A	Y	2		
		31236	91 THE LAURELS, ENF	A	Y	2		
		31237	93 THE LAURELS, ENF	A	Y	2		
		31238	125 THE LAURELS, ENF	A	Y	2		
		31239	131 THE LAURELS, ENF	A	Y	2		
		31240	147 THE LAURELS, ENF	A	Y	2		
		31241	161 THE LAURELS, ENF	A	Y	2		
		31242	165 THE LAURELS, ENF	A	Y	2		
		31243	167 THE LAURELS, ENF	A	Y	2		
		31244	240 ALEWIFE LN, SFD	A	Y	2		
		31245	244 ALEWIFE LN, SFD	A	Y	2		
		31246	256 ALEWIFE LN, SFD	A	Y	2		
		31247	258 ALEWIFE LN, SFD	A	Y	2		
		31248	262 ALEWIFE LN, SFD	A	Y	2		
		31249	266 ALEWIFE LN, SFD	A	Y	2		
		31250	268 ALEWIFE LN, SFD	A	Y	2		
		31251	270 ALEWIFE LN, SFD	A	Y	2		
		31252	272 ALEWIFE LN, SFD	A	Y	2		
		31253	2 AMBLESIDE CT, SFD	A	Y	2		
		31254	5 AMBLESIDE CT, SFD	A	Y	2		
		31255	5 CANBORNE WAY, SFD	A	Y	2		
		31256	8 CANBORNE WAY, SFD	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31257	9 CANBORNE WAY, SFD	A	Y	2		
		31258	10 CANBORNE WAY, SFD	A	Y	2		
		31259	11 CANBORNE WAY, SFD	A	Y	2		
		31260	163 COHO LN, SFD	A	Y	2		
		31261	167 COHO LN, SFD	A	Y	2		
		31262	171 COHO LN, SFD	A	Y	2		
		31263	173 COHO LN, SFD	A	Y	2		
		31264	4 CURRYCROSS CT, SFD	A	Y	2		
		31265	5 CURRYCROSS CT, SFD	A	Y	2		
		31266	6 CURRYCROSS CT, SFD	A	Y	2		
		31267	10 DEEP BRK HRBR, SF	A	Y	2		
		31268	14 DEEP BRK HRBR, SF	A	Y	2		
		31269	24 DEEP BRK HRBR, SF	A	Y	2		
		31270	30 DEEP BRK HRBR, SF	A	Y	2		
		31271	2 DOWNING WAY, SFD	A	Y	2		
		31272	4 DOWNING WAY, SFD	A	Y	2		
		31273	5 DOWNING WAY, SFD	A	Y	2		
		31274	7 DOWNING WAY, SFD	A	Y	2		
		31275	8 DOWNING WAY, SFD	A	Y	2		
		31276	10 DOWNING WAY, SFD	A	Y	2		
		31277	15 DOWNING WAY, SFD	A	Y	2		
		31278	160 DUSKY LN, SFD	A	Y	2		
		31279	166 DUSKY LN, SFD	A	Y	2		
		31280	170 DUSKY LN, SFD	A	Y	2		
		31281	178 DUSKY LN, SFD	A	Y	2		
		31282	182 DUSKY LN, SFD	A	Y	2		
		31283	186 DUSKY LN, SFD	A	Y	2		
		31284	188 DUSKY LN, SFD	A	Y	2		
		31285	190 DUSKY LN, SFD	A	Y	2		
		31286	202 DUSKY LN, SFD	A	Y	2		
		31287	206 E BASS LN, SFD	A	Y	2		
		31288	214 E BASS LN, SFD	A	Y	2		
		31289	216 E BASS LN, SFD	A	Y	2		
		31290	222 E BASS LN, SFD	A	Y	2		
		31291	226 E BASS LN, SFD	A	Y	2		
		31292	112 E BLUE GLL, SFD	A	Y	2		
		31293	114 E BLUE GLL, SFD	A	Y	2		
		31294	116 E BLUE GLL, SFD	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31295	120 E BLUE GLL, SFD	A	Y	2		
		31296	136 E BLUE GLL, SFD	A	Y	2		
		31297	142 E GRYLNG, SFD	A	Y	2		
		31298	152 E GRYLNG, SFD	A	Y	2		
		31299	3 MAYBURY RD, SFD	A	Y	2		
		31300	11 MAYBURY RD, SFD	A	Y	2		
		31301	12 MAYBURY RD, SFD	A	Y	2		
		31302	123 MOUNTAIN RD, SFD	A	Y	2		
		31303	6 BAMFORTH RD 11, VN	A	Y	2		
		31304	6 BAMFORTH RD 18, VN	A	Y	2		
		31305	6 BAMFORTH RD 19, VN	A	Y	2		
		31306	6 BAMFORTH RD 5, VN	A	Y	2		
		31307	6 BAMFORTH RD 6, VN	A	Y	2		
		31308	6 BAMFORTH RD 8, VN	A	Y	2		
		31309	6 BAMFORTH RD 9, VN	A	Y	2		
		31310	444 CRICKET CIR, VN	A	Y	2		
		31311	451 CRICKET CIR, VN	A	Y	2		
		31312	453 CRICKET CIR, VN	A	Y	2		
		31313	458 CRICKET CIR, VN	A	Y	2		
		31314	450 CRICKET CIR, VN	A	Y	2		
		31315	43 FRANKLIN ST B, VN	A	Y	2		
		31316	413 LADYBUG LN, VN	A	Y	2		
		31317	425 LADYBUG LN, VN	A	Y	2		
		31318	105 MAPLE AVE 1, VN	A	Y	2		
		31319	105 MAPLE AVE 10, VN	A	Y	2		
		31320	105 MAPLE AVE 12, VN	A	Y	2		
		31321	105 MAPLE AVE 13, VN	A	Y	2		
		31322	105 MAPLE AVE 14, VN	A	Y	2		
		31323	105 MAPLE AVE 15, VN	A	Y	2		
		31324	105 MAPLE AVE 16, VN	A	Y	2		
		31325	105 MAPLE AVE 17, VN	A	Y	2		
		31326	105 MAPLE AVE 18, VN	A	Y	2		
		31327	105 MAPLE AVE 19, VN	A	Y	2		
		31328	105 MAPLE AVE 2, VN	A	Y	2		
		31329	105 MAPLE AVE 20, VN	A	Y	2		
		31330	105 MAPLE AVE 21, VN	A	Y	2		
		31331	105 MAPLE AVE 22, VN	A	Y	2		
		31332	105 MAPLE AVE 23, VN	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31333	105 MAPLE AVE 24, VN	A	Y	2		
		31334	105 MAPLE AVE 25, VN	A	Y	2		
		31335	105 MAPLE AVE 27, VN	A	Y	2		
		31336	105 MAPLE AVE 28, VN	A	Y	2		
		31337	105 MAPLE AVE 29, VN	A	Y	2		
		31338	105 MAPLE AVE 3, VN	A	Y	2		
		31339	105 MAPLE AVE 30, VN	A	Y	2		
		31340	105 MAPLE AVE 31, VN	A	Y	2		
		31341	105 MAPLE AVE 32, VN	A	Y	2		
		31342	105 MAPLE AVE 36, VN	A	Y	2		
		31343	105 MAPLE AVE 37, VN	A	Y	2		
		31344	105 MAPLE AVE 39, VN	A	Y	2		
		31345	105 MAPLE AVE 4, VN	A	Y	2		
		31346	105 MAPLE AVE 40, VN	A	Y	2		
		31347	105 MAPLE AVE 41, VN	A	Y	2		
		31348	105 MAPLE AVE 42, VN	A	Y	2		
		31349	105 MAPLE AVE 43, VN	A	Y	2		
		31350	105 MAPLE AVE 44, VN	A	Y	2		
		31351	105 MAPLE AVE 45, VN	A	Y	2		
		31352	105 MAPLE AVE 46, VN	A	Y	2		
		31353	105 MAPLE AVE 5, VN	A	Y	2		
		31354	105 MAPLE AVE 7, VN	A	Y	2		
		31355	105 MAPLE AVE 8, VN	A	Y	2		
		31356	105 MAPLE AVE 9, VN	A	Y	2		
		31357	55 OLD TWN, VN	A	Y	2		
		31358	60 OLD TWN 100, VN	A	Y	2		
		31359	60 OLD TWN 102, VN	A	Y	2		
		31360	60 OLD TWN 118, VN	A	Y	2		
		31361	60 OLD TWN 119, VN	A	Y	2		
		31362	60 OLD TWN 124, VN	A	Y	2		
		31363	60 OLD TWN 127, VN	A	Y	2		
		31364	60 OLD TWN 128, VN	A	Y	2		
		31365	60 OLD TWN 129, VN	A	Y	2		
		31366	60 OLD TWN 141, VN	A	Y	2		
		31367	60 OLD TWN 154, VN	A	Y	2		
		31368	60 OLD TWN 155, VN	A	Y	2		
		31369	60 OLD TWN 157, VN	A	Y	2		
		31370	60 OLD TWN 159, VN	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31371	60 OLD TWN 162, VN	A	Y	2		
		31372	60 OLD TWN 164, VN	A	Y	2		
		31373	60 OLD TWN 165, VN	A	Y	2		
		31374	60 OLD TWN 167, VN	A	Y	2		
		31375	60 OLD TWN 168, VN	A	Y	2		
		31376	60 OLD TWN 172, VN	A	Y	2		
		31377	60 OLD TWN 174, VN	A	Y	2		
		31378	60 OLD TWN 179, VN	A	Y	2		
		31379	60 OLD TWN 187, VN	A	Y	2		
		31380	60 OLD TWN 193, VN	A	Y	2		
		31381	60 OLD TWN 195, VN	A	Y	2		
		31382	60 OLD TWN 199, VN	A	Y	2		
		31383	60 OLD TWN 3, VN	A	Y	2		
		31384	70 OLD TWN 302, VN	A	Y	2		
		31385	70 OLD TWN 319, VN	A	Y	2		
		31386	70 OLD TWN 320, VN	A	Y	2		
		31387	70 OLD TWN 322, VN	A	Y	2		
		31388	70 OLD TWN 323, VN	A	Y	2		
		31389	70 OLD TWN 328, VN	A	Y	2		
		31390	70 OLD TWN 330, VN	A	Y	2		
		31391	70 OLD TWN 338, VN	A	Y	2		
		31392	70 OLD TWN 343, VN	A	Y	2		
		31393	70 OLD TWN 350, VN	A	Y	2		
		31394	70 OLD TWN 357, VN	A	Y	2		
		31395	70 OLD TWN 369, VN	A	Y	2		
		31396	70 OLD TWN 381, VN	A	Y	2		
		31397	60 OLD TWN 57, VN	A	Y	2		
		31398	60 OLD TWN 59, VN	A	Y	2		
		31399	60 OLD TWN 64, VN	A	Y	2		
		31400	60 OLD TWN 65, VN	A	Y	2		
		31401	60 OLD TWN 67, VN	A	Y	2		
		31402	60 OLD TWN 70, VN	A	Y	2		
		31403	60 OLD TWN 72, VN	A	Y	2		
		31404	60 OLD TWN 76, VN	A	Y	2		
		31405	60 OLD TWN 82, VN	A	Y	2		
		31406	60 OLD TWN 83, VN	A	Y	2		
		31407	60 OLD TWN 9, VN	A	Y	2		
		31408	20 PROGRESS AVE B, V	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31409	401 TALCTVILLE 104, V	A	Y	2		
		31410	401 TALCTVILLE 107,	A	Y	2		
		31411	98 W MAIN ST, VN	A	Y	2		
		31412	94 WEST ST 10, VN	A	Y	2		
		31413	100 WEST ST 101, VN	A	Y	2		
		31414	100 WEST ST 105, VN	A	Y	2		
		31415	100 WEST ST 106, VN	A	Y	2		
		31416	35 CHURCH ST, WL	A	Y	2		
		31417	59 DOVE CT, WL	A	Y	2		
		31418	69 DOVE CT, WL	A	Y	2		
		31419	26 MEADOW LN, WL	A	Y	2		
		31420	30 MEADOW LN, WL	A	Y	2		
		31421	32 MEADOW LN, WL	A	Y	2		
		31422	102 ORCH HILL DR, WL	A	Y	2		
		31423	2 PARTRIDGE CT, WL	A	Y	2		
		31424	4 PARTRIDGE CT, WL	A	Y	2		
		31425	6 PARTRIDGE CT, WL	A	Y	2		
		31426	8 PARTRIDGE CT, WL	A	Y	2		
		31427	10 PARTRIDGE CT, WL	A	Y	2		
		31428	12 PARTRIDGE CT, WL	A	Y	2		
		31429	14 PARTRIDGE CT, WL	A	Y	2		
		31430	16 PARTRIDGE CT, WL	A	Y	2		
		31431	18 PARTRIDGE CT, WL	A	Y	2		
		31432	20 PARTRIDGE CT, WL	A	Y	2		
		31433	22 PARTRIDGE CT, WL	A	Y	2		
		31434	24 PARTRIDGE CT, WL	A	Y	2		
		31435	31 PHEASANT CT, WL	A	Y	2		
		31436	35 PHEASANT CT, WL	A	Y	2		
		31437	43 PHEASANT CT, WL	A	Y	2		
		31438	3 QUAIL CT, WL	A	Y	2		
		31439	5 QUAIL CT, WL	A	Y	2		
		31440	9 QUAIL CT, WL	A	Y	2		
		31441	19 QUAIL CT, WL	A	Y	2		
		31442	21 QUAIL CT, WL	A	Y	2		
		31443	MDBK APT 1	A	Y	N		
		31444	30 BENJAMIN WAY, SW	A	Y	1		
		31445	35 BENJAMIN WAY, SW	A	Y	1		
		31446	36 BENJAMIN WAY, SW	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		31447	MDBK APT 2	A	Y	N		
		31448	MDBK APT 3	A		N		
		31449	MDBK APT 4	A	Y	N		
		31450	MDBK APT 5	A	Y	N		
		31451	MDBK APT 6	A	Y	N		
		31452	MDBK APT 7	A	Y	N		
		31453	MDBK APT 8	A	Y	N		
		31454	MDBK APT 9	A	Y	N		
		31455	MDBK APT 10	A	Y	N		
		31456	MDBK APT 11	A	Y	N		
		31457	MDBK APT 12	A	Y	N		
		31458	MDBK APT 13	A	Y	N		
		31459	MDBK APT 14	A	Y	N		
		31460	MDBK APT 15	A	Y	N		
		31461	MDBK APT 16	A	Y	N		
		31462	MDBK APT 17	A	Y	N		
		31463	MDBK APT 18	A	Y	N		
		31464	MDBK APT 19	A	Y	N		
		31465	MDBK APT 20	A	Y	N		
		31466	7 LEON ST, ENF7 LEON	A	Y	1		
		3150	3150 STAFFORD TOWN H	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		4050	P.O., BROAD BROOK	A	Y			
		4150	TOWN HALL ROUTE 190	A	Y			
		4163	INTERCONNECT PIT 4 B	A	Y			
		6050	MOBIL MRT 30/31,ROCK	A	Y			
		6051	WEST ST. PS, ROCKVL	A	Y			
		6052	SERAPHN FRD,R.83,RCK	A	Y			
		6053	AUTM C,115 WST R,ELL	A	Y			
		6054	WAPPING WOOD TSS,SW	A	Y			
		6055	P.O.,R.83,TALCTTVL	A	Y		Y	
		6056	TOWN HALL, ELLINGTON	A	Y			Y
		6057	TALLWD PRV PT, VRN	A	Y			
		6058	COMFRT,425 HFD TK,VN	A	Y			
		6059	SADDS ML SS, ELNGTN	A	Y			
		6060	ELLINGTON HIGH SCHOO	A	Y			
		6150	LIBRARY, TOLLND	A	Y			
		6550	HERITAGE WOODS, TOLL	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW001	CLUB HOUSE	A	Y	N	Y	Y
		MW002	23 HILL POND	A	Y	3		
		MW003	30 OLDWOOD	A	Y	3		
		MW004	MAINTENANCE BLDG	A	Y	N		
		MW005	2 MAPLEWOOD	A	Y	3		
		MW006	8 RIDGE CIRCLE	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - ROCKVILLE WTP	3	ENTRY POINT - ROCKVI	A				
00701	ENTRY POINT - HUNT WELLFIELD	3	EP-HUNT WELLFIELD	A				
00702	ENTRY POINT - POWDER HOLLOW WELL FIELD	3	EP - POWDER HOLLOW W	A				
00703	ENTRY POINT - SPRING LOTS WELLFIELD	3	EP - SPRING LOTS	A				
00705	ENTRY POINT - VERNON WELL 1	3	EP-VERNON WELL 1	A				
00706	ENTRY POINT - VERNON WELL 2	3	EP-VERNON WELL 2	A				
00708	ENTRY POINT - VERNON WELL 4	3	EP-VERNON WELL 4	A				
00709	ENTRY POINT - VERNON WELL 5	3	EP-VERNON WELL 5	A				
00712	ENTRY POINT - WINDSOR LOCKS PUMP STATION	2	RAW WATER	A				
		3	EP-WINDSOR LOCKS PS	A				
00713	ENTRY POINT - WOODLAND PARK WELL	3	EP-WOODLAND PARK	A				
00714	ENTRY POINT - PINE KNOB WELL	3	EP-PINE KNOB WELL	A				
00715	ENTRY POINT - WEST SUFFIELD WELL	3	EP-WEST SUFFIELD	A				
00716	ENTRY POINT - MAPLETON STATION	3	EP-MAPLETON STATION	A				
00719	ENTRY POINT - O'BREADY	3	EP-O'BREADY	A				
00721	ENTRY POINT - ELLINGTON ACRES TREATMT PLT	3	ENTRY POINT - ELLINGT	A				
00722	ENTRY POINT - PRESTON WELL #1	3	ENTRY POINT - PRESTO	A				
1245	SPRING LOTS WELL 3	2	WELL SPRING LOTS 3	A				
1247	SPRING LOTS WELL 5	2	SPRING LOTS WELL 5	A				
1267	O'BREADY WELL	2	O'BREADY WELL	A				
1268	POWDER HOLLOW WELL 1	2	POWDER HOLLOW WELL 1	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
1278	HUNT WELL 5	2	HUNT WELL 5	A				
1279	HUNT WELL 6	2	HUNT WELL 6	A				
1281	HUNT WELL 8	2	HUNT WELL 8	A				
1282	HUNT WELL 9	2	HUNT WELL 9	A				
1314	VERNON WELL 1	2	VERNON WELL 1	A				
1315	VERNON WELL 2	2	VERNON WELL 2	A				
1316	VERNON WELL 4	2	VERNON WELL 4	A				
1636	VERNON WELL #5	2	VERNON WELL #5 - R	A				
1637	VERNON WELL #4							
168	PINE KNOB WELL	2	PINE KNOB WELL	A				
169	WOODLAND PARK WELL	2	WOODLAND PARK WELL	A				
177	VERNON WELL 5	2	VERNON WELL 5	A				
1937	HUNT WELL 10	2	HUNT WELL 10	A				
1938	POWDER HOLLOW WELL 4	2	PH WELL 4	A				
2077	SHENIPSIT LAKE	1	SHENIPSIT LAKE	A				
255	PRESTON WELL #1 TREATMENT PLANT							
30029	LAKE SHENIPSIT							
38	WEST SUFFIELD WELL	2	WEST SUFFIELD WELL	A				
4	MAPLETON AVE WELL 2	2	MAPLETON AVE WELL 2	A				
47835	SPRING LOTS WELL 7	2	SPRING LOTS WELL 7	A				
50075	ELLINGTON ACRES TREATMENT PLANT							
51205	PROSPECT HILL STORAGE TANK							
51207	WAPPING WOOD (SOUTH WINDSOR) STANDPIPE 1							
51219	ELM ST TANK							
51221	MILDRED ST TANK							
51223	SUFFIELD INDUSTRIAL PARK TANK							
51225	TOLLAND (HERITAGE WOODS) STORAGE TANK							
51227	TOLLAND (HERITAGE WOODS) HD TANKS (2)							
51235	VERNON WELL 1 HYDROPNEUMATIC TANKS							
51243	SUFFIELD - NORTH ST TANK							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
51245	ENFIELD ST TANK -0.5 MG							
51247	ENFIELD ST TANK - 1.5 MG							
51249	BRAINARD ROAD TANK #1							
51251	SNIPSIC STREET TANK							
51253	ROCKVILLE WTP CLEARWELLS							
51255	SOUTH ST TANK							
51257	SUFFIELD BOOSTER STATION 1							
51259	SUFFIELD BOOSTER STATION 2							
51261	SADDS MILL BOOSTER STATION							
51263	WEST ST BOOSTER STATION							
51265	TOLLAND BOOSTER STATION							
51267	OLD COUNTY RD BOOSTER STATION							
51269	ENFIELD ST BOOSTER STATION							
52905	SPRING LOTS WELL 8	2	SPRING LOTS WELL 8	A				
53579	WAPPING WOOD TANK 2							
54663	INTERCONNECTION-MDC -RT. 5							
54665	INTERCONNECTION-MDC -OLD COUNTY RD							
54669	INTERCONNECTION-MDC - SCHOEPHOESTER RD							
54961	SPRING LOTS WELL 9	2	SPRING LOTS WELL 9	A				
55943	SHAKER ROAD PUMP STATION							
56751	PRESTON WELL #1	2	PRESTON WELL #1	A				
59103	DAVID DRIVE BOOSTER PUMP STATION							
59582	TIMBER LANE TANKS (OLD ELLINGTON ACRES)							
59584	GULF ROAD TANK							
59586	BRAINARD ROAD TANK #2							
59713	POWDER HOLLOW WELL 5	2	POWDER HOLLOW WELL 5	A				
60576	ROCKVILLE WATER TREATMENT PLANT							
60779	ELLINGTON ACRES PUMPHOUSE ATM TANKS							
60781	TOLLAND HERITAGE WOODS BPS							
60846	GRAND LOFTS PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
60856	BRADLEY TANK #1							
60858	BRADLEY TANK #2							
60860	BRADLEY TANK #3							
612	O'BREADY WELL TREATMENT PLANT							
613	PINE KNOB WELL TP							
614	WOODLAND PARK WELL TP							
66	ELLINGTON ACRES WELL #3	2	ELLINGTON ACRES WELL	A				
67	ELLINGTON ACRES WELL #2	2	ELLINGTON ACRES WELL	A				
68	ELLINGTON ACRES WELL #1	2	WELL 1	A				
71	HUNT WATER TREATMENT PLANT	3	EP - HUNT WTP	A				
72	VERNON WELL #1							
73	VERNON WELL #2	3	EP - VERNON WELL #2	A				
74	POWDER HOLLOW WELLS							
75	MAPLETON STATION	3	EP -MAPLETON STATION	A				
77	SPRING LOTS TREATMENT PLANT							
XX700	ENTRY POINT - ROCKVILLE WTP	3X	EP-ROCKVILLE WTP	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
GREEN, III, CLIFFORD	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2020
LABIANCA, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
WATERHOUSE, KEITH B.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2020

Water System Facility: HUNT WATER TREATMENT PLANT (WSF ID: 71)

Facility Classification: CLASS 2 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Certified Operator Information

Water System Facility: VERNON WELL #1 (WSF ID: 72)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: VERNON WELL #2 (WSF ID: 73)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: POWDER HOLLOW WELLS (WSF ID: 74)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: MAPLETON STATION (WSF ID: 75)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: SPRING LOTS TREATMENT PLANT (WSF ID: 77)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020

Water System Facility: VERNON WELL #4 (WSF ID: 1637)

Facility Classification: CLASS 1 TREATMENT PLANT

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							36,248	

Towns Served:

Certified Operator Information

Water System Facility: VERNON WELL #4 (WSF ID: 1637)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020

Water System Facility: VERNON WELL #5 (WSF ID: 1636)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: O'BREADY WELL TREATMENT PLANT (WSF ID: 612)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: WOODLAND PARK WELL TP (WSF ID: 614)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: PINE KNOB WELL TP (WSF ID: 613)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Water System Facility: ELLINGTON ACRES TREATMENT PLANT (WSF ID: 50075)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	98,390	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						36,248	

Towns Served:

Certified Operator Information

Water System Facility: PRESTON WELL #1 TREATMENT PLANT (WSF ID: 255)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Contact Information

Name		Organization		Job Title		
Mr. Craig J. Patla		Connecticut Water Company		Vp, Service Delivery		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6140				800-391-1924	cpatla@ctwater.com	

Contact Role(s): Legal Contact

Name		Organization		Job Title		
Connecticut Water Company						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-669-8630				800-286-5700	info@ctwater.com	

Contact Role(s): Owner

Name		Organization		Job Title		
Mr. David Connors		Connecticut Water Company		Director, Service De		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
		93 West Main St		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6141				860-227-4902	dconnors@ctwater.com	

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470044	MARKOWSKI FARMS			C	155	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
42 PLANTATION ROAD							2

Towns Served: EAST WINDSOR

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		

Total Coliform (3100) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Lead And Copper (PBCU) 5 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/20	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **ENTRY POINT - DORM (WSF ID: 00701)**

Nitrate (1040) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - DORM (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Nitrite (1041) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - DORM (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - DORM (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per six years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - DORM (3)	1/1/14 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470044	MARKOWSKI FARMS			C	155	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
42 PLANTATION ROAD							2
Towns Served: EAST WINDSOR							

Monitoring Requirements

Water System Facility: ENTRY POINT - DORM (WSF ID: 00701)

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per six years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/25		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - DORM (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - DORM (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: WELL (WSF ID: 20861)

E. Coli (3014) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	8/12/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification Required</i>	<i>Public Notification Performed</i>	<i>PN Certification Due to DPH</i>	<i>PN Certification Received</i>
REVISED TOTAL COLIFORM RULE (RTCR)	4/15/18 - 5/7/18	3	6/6/2019		6/16/2019	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	01	KITCHEN	A	Y			
		02	LOWER BATH SINK #1	A	Y			
		03	LOWER BATH SINK #4	A	Y			
		04	UPPER BATH TO RIGHT	A	Y			
		05	UPPER BATH BY URINAL	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470044	MARKOWSKI FARMS			C	155	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
42 PLANTATION ROAD							2
Towns Served: EAST WINDSOR							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - DORM	3	EP - DORM	A				
20861	WELL	2	WELL	A				
47945	WTP1 - OFFICE GAC							
47947	WTP2 - DORM GAC							
47949	WTP3 - WELLHOUSE #1 GAC							
55673	DORM - BLADDER TANK							
55675	PUMPHOUSE - BLADDER TANK							

Certified Operator Information

Water System Facility: **WTP1 - OFFICE GAC (WSF ID: 47945)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SNEDEKER, MICHAEL A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019

Water System Facility: **WTP2 - DORM GAC (WSF ID: 47947)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SNEDEKER, MICHAEL A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019

Water System Facility: **WTP3 - WELLHOUSE #1 GAC (WSF ID: 47949)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SNEDEKER, MICHAEL A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019

Contact Information

Name				Organization				Job Title		
Markowski Farms										
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
216 Babbs Road							West Suffield		CT	06093
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone	Email Address		
Contact Role(s):		Owner								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0470044	MARKOWSKI FARMS	C	155	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
42 PLANTATION ROAD					
Towns Served: EAST WINDSOR					
Name		Organization		Job Title	
Mr. John Markowski		Markowski Farms		Co-Owner	
Mailing Address Line One		Mailing Address Line Two		City	State
216 Babbs Rd				West Suffield	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-668-2881				860-655-6382	
Contact Role(s): Legal Contact, Owner					
Name		Organization		Job Title	
Mr. Robert Markowski		Markowski Farm		Owner	
Mailing Address Line One		Mailing Address Line Two		City	State
216 Babbs Rd				West Suffield	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-604-8659		860-668-7621		860-668-2881	missbailey4616@cox.net
Contact Role(s): Administrative Contact, Legal Contact, Owner					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.